

Residential Photovoltaic Arrays

Matt Kane

ENCE 627 Fall 2002

Semester Project

Dec 3, 2002

Project Objectives

- **Minimize Payback Period**
 - ❖ **Least Expensive Array**
 - ❖ **Aesthetics a concern**
- **Maximize Power Output**
 - ❖ **Limited Roof Area**
 - ❖ **Roof Orientation a concern**

Site Description

- **2 Story Colonial Built in 1999.**
- **Approximately 1,990 square feet.**
 - About 566 sq. ft. of usable roof area.
- **Average electricity consumption 13,800 kWh/year.**
- **US 1997 average electrical consumption per household was 10,215 kWh/yr.**


Site Description

- **Roof area faces west - lots of afternoon sun. Not ideal, but still acceptable due to lack of shading.**
- **Electricity consumption correlates with available solar energy.**




Weather Analysis

Research Data, Laurel MD.



- Laurel research consists of 30 year averages.
- For the chart below, the definition of "sunshine" was not found.



Array Competitive Analysis

- **Array must be integrated into roof.**
 - Community association covenants
 - Lack of suitable yard area
- **Aesthetically pleasing**
 - Low visual impact
- **All PV arrays are expensive at this time.**

FOR MORE INFO...

- <https://www.altenergystore.com/cart/1130?cQdmRWjo;>
- <http://www.cetsolar.com/architecturalssp.htm>

Array Competitive Analysis

- **Raised Seam Roofing**
- **Cheapest per watt in terms of materials and labor.**
- **May not be pleasing due to industrial appearance.**
- **Comes in 64 or 128 watt sizes.**



A 1.5 kW DC system was installed on a National Association of Home Builders (NAHB) 21st Century Townhouse in Maryland. The 18-panel system is grid connected. It has a 16-kWh battery backup

Array Competitive Analysis

- **Shingle type arrays**
 - Larger capacity array per area
- **More expensive**
 - More modules
 - More labor because of additional roof penetrations and wiring issues.




A 2.0 kilowatt DC grid-connected system operating at the Southface Energy & Environmental Resource Center in Atlanta, Georgia. The grid-connected system is configured at 48 volts DC using a 4,000 watt inverter.

Uncertainties

- **Four major categories**
 - **Installation and materials costs**
 - **Power generated (reduced monthly bills)**
 - **Electricity Rates**
 - **Interest Rates**

Uncertainties

- **Installation and materials cost**
 - Called local installers to get a feel for pricing. Decided a uniform distribution between \$11,000 and \$15,000 per kW capacity adequately represented potential installation costs.



Uncertainties

- **Power Generated**

- Used Department of Energy’s web application “PV WATTS” to estimate electrical power generated by arrays of different sizes.



Station Identification	
Cell ID:	263375
State:	
Latitude:	39.1 ° N
Longitude:	76.9 ° W
PV System Specifications	
AC Rating	4.00 kW
Array Type	
Array Tilt:	36.9 °
Array Azimuth:	270.0 °
Energy Specifications	
UtilityCost/kWh	\$0.07
UtilityCost (summer)/kWh:	\$0.09

Month	Energy	Energy Value
	(kWh)	(\$)
1	228	\$ 15.75
2	271	\$ 18.72
3	461	\$ 31.85
4	507	\$ 35.03
5	580	\$ 40.08
6	583	\$50.76
7	585	\$50.93
8	512	\$44.58
9	434	\$37.79
10	355	\$ 24.53
11	226	\$ 15.62
12	194	\$ 13.40
Year	4936	\$ 379.04

Uncertainties

- **Electricity Rates**


- I collected 23 months of data for my house.
- Non Summer rates averaged about \$0.07/kWh
- Summer Rates averaged around \$0.09/kWh
- I decided a uniform distribution for each rate with a mean as above and a standard deviation of 0.05 best represented my uncertainty about the electricity rates.



Uncertainties

- **Interest Rates**

- The project would have to be financed.
- Interest rates are currently very low.
- I felt that interest rates are more likely to rise than they are to fall. I chose a beta distribution to represent my uncertainty about future interest rates.






Simulation

- **Used @RISK to perform Monte Carlo simulation.**
 - 4 different array sizes were evaluated up to 3.3 kW.
 - 5000 iterations were performed to get good convergence.
- **@RISK Inputs**
 - Non Summer Rates
 - Summer Rates
 - Cost/kW Installed
 - Installed Capacity
 - Interest Rate
- **Also calculated array cost and payback period (Present Value).**
 - Payback Equation: $PV=R*\{[(1+i)^n-1]/[i*(1+i)^n]\}$ where PV is the present value cost of the array, R is the regular payments made, i is the annual interest rate (compounded annually), and n is the number of years it takes to pay the loan.

Simulation


- Performed Sensitivity Analysis.
 - In all cases, Cost/kW installed was the greatest impact on the payback period.



Simulation

- Checked for Dominance.

- The 128 W raised seam units dominates the simulation, as the payback period is lowest by a small margin.
- Payback period remains the same within a specific unit regardless of the capacity installed.



Conclusions and Strategy

- **Despite increasing popularity in some applications and improved manufacturing techniques, PV arrays are still VERY expensive.**
- **Installation costs for the homeowner are prohibitively high.**
- **Interest rates are not likely to drop any further.**

Conclusions and Strategy

- **Payback periods are on the order of a mortgage loan (15-30 years).**
- **Electricity costs are reasonable.**
- **PV is NOT a cost effective alternative in for the average DC Metro area homeowner.**